



Centrum stovebního inženýrství a.s.

Fire Technical Laboratory

AUTHORIZED
BODY No. 212

NOTIFIED
BODY No. 1390

Initial type testing report No. ITT-06-072

of product

Fatrafol 804

on behalf of: **Fatra, a.s.**
tř. T. Bati 1541
763 61 Napajedla
Czech Republic

Job No. PTL - 126/06

Assessed property of the product: ČSN EN 13501-1 Fire classification of construction products and building elements – Part 1: Classification using test data from reaction to fire tests.

Prague, September 2006

This initial type testing report includes 3 pages

1. DETAILS OF THE PRODUCT

Nature and end use application:

The product *Fatrafol 804* is defined as a „type of classified product“. Its classification is valid for the following end use application: Flexible sheet for waterproofing.

Technical specification: ČSN EN 13956 Flexible sheet for waterproofing – Plastics and rubber sheets for roof waterproofing – Definitions and characteristics.

Description:

The product *Fatrafol 804* is fully described in the test reports in support of the classification listed in clause 2.

2. UESD DOCUMENTS

Executor	Type of document	Test report ref. no.	Standard
CSI a.s., PTL	test report	13127	ČSN EN ISO 11925-2
CSI a.s., PTL	reaction to fire classification report	PK-06-072	ČSN EN 13501-1
Fatra, a.s.	sampling entry		ČSN EN 13416

Classification of the product

The product *Fatrafol 804*, in relation to its reaction to fire behaviour is classified:

E

3. LIMITATIONS

Conditions of using and validity of initial type testing report

This initial type testing report is valid for the above-mentioned product and can be used for this product only. The initial type testing report shall not be reproduced except in full without the written approval of the Notified Body no. 1390. The initial type testing report remains valid, as long as the facts, especially the features of the product under which were the tests and classification done, do not change.

Date: 29th September 2006

Prepared:



Vít Slaboch



Reviewed:


Pavel Vaniš Ph.D, CEng.
head of Division of fire safety